

C_3.1.4. Determination of heating loads

TRANSMISSION FLUX	H	ϑ^*	ϑ^*	ϕ
	[W/K]	[°C]	[°C]	[W]
	39617.34	20.00	-8.00	1109285.58
	2367.85	20.00	-8.00	66299.84
	1320.00	20.00	-8.00	36960.00
	671.19	20.00	-8.00	18793.22
TOTAL ϕ_c				1231338.64

VENTILATION FLUX	H	ϑ^*	ϑ^*	ϕ
	[W/K]	[°C]	[°C]	[W]
	18122.5	20.0	-8.0	507431.2
TOTAL ϕ_a				507431.232

INTERMITTANCE FLUX	As	f	$\Delta\theta$ n	ϕ
	[m²]	[W/m²]	[K] [h]	[W]
	11220.0	36.0	1.0	403920.0
			TOTAL ϕ_a	403920

TOTAL FLUX	ϕ_c	ϕ_a	ϕ_{int}	ϕ_{TOT}
	[W]	[W]	[W]	[W]
	1231339	507431.2	403920	2142689.872
			ϕ_{TOT}/mq	190.9705769

FLUX INCIDENCE

