



VERIFICATION OF THE COMPLIANCE WITH ITALIAN REGULATIONS ABOUT AIR / LIGHT RATIO

Building A					
ID	Floor area [m²]	Transparent area [m²]	Air/light ratio	Minimum air/light ratio	Verified?
Classroom 1	46,06	15,75	0,341	0,125	YES
Classroom 2	46,29	10,50	0,226	0,125	YES
Classroom 3	46,29	10,50	0,226	0,125	YES
Classroom 4	46,29	10,50	0,226	0,125	YES
Classroom 5	22,56	10,50	0,465	0,125	YES
Classroom 6	22,56	10,50	0,465	0,125	YES
Classroom 7	46,29	10,50	0,226	0,125	YES
Classroom 8	46,29	10,50	0,226	0,125	YES
Classroom 9	46,29	10,50	0,226	0,125	YES
Classroom 10	46,30	10,50	0,226	0,125	YES
Classroom 11	46,53	10,50	0,225	0,125	YES
Classroom 12	46,29	10,50	0,226	0,125	YES
Classroom 13	46,29	10,50	0,465	0,125	YES
Classroom 14	46,29	10,50	0,465	0,125	YES
Classroom 15	22,56	10,50	0,226	0,125	YES
Classroom 16	22,56	10,50	0,226	0,125	YES
Classroom 17	46,29	10,50	0,226	0,125	YES
Classroom 18	46,29	10,50	0,225	0,125	YES
Classroom 19	46,29	10,50	0,132	0,125	YES
Classroom 20	46,53	10,50	0,226	0,125	YES
Classroom 21	46,30	6,13	0,226	0,125	YES
Classroom 22	46,29	10,50	0,226	0,125	YES
Classroom 23	46,29	10,50	0,228	0,125	YES
Classroom 24	46,29	10,50	0,228	0,125	YES
Classroom 25	46,06	10,50	0,226	0,125	YES
Classroom 26	46,06	10,50	0,226	0,125	YES

ID	Floor area [m²]	Transparent area [m²]	Air/light ratio	Minimum air/light ratio	Verified?
Classroom 27	46,29	10,50	0,226	0,125	YES
Classroom 28	46,29	10,50	0,226	0,125	YES
Classroom 29	46,29	10,50	0,226	0,125	YES
Classroom 30	46,30	6,13	0,132	0,125	YES
Classroom 31	46,53	10,50	0,225	0,125	YES
Classroom 32	46,29	10,50	0,226	0,125	YES
Classroom 33	46,29	10,50	0,226	0,125	YES
Classroom 34	46,29	10,50	0,226	0,125	YES
Classroom 35	22,56	10,50	0,465	0,125	YES
Classroom 36	22,56	10,50	0,465	0,125	YES
Classroom 37	46,29	10,50	0,226	0,125	YES
Classroom 38	46,29	10,50	0,226	0,125	YES
Classroom 39	46,29	10,50	0,226	0,125	YES
Classroom 40	46,53	10,50	0,225	0,125	YES
Classroom 41	46,30	10,50	0,226	0,125	YES
Classroom 42	46,29	10,50	0,226	0,125	YES
Classroom 43	46,29	10,50	0,226	0,125	YES
Classroom 44	46,29	10,50	0,226	0,125	YES
Classroom 45	22,56	10,50	0,465	0,125	YES
Classroom 46	22,56	10,50	0,465	0,125	YES
Classroom 47	46,29	10,50	0,226	0,125	YES
Classroom 48	46,29	10,50	0,226	0,125	YES
Classroom 49	46,29	10,50	0,226	0,125	YES
Classroom 50	46,06	15,75	0,341	0,125	YES
Corridor 01	922,42	158,70	0,172	0,1	YES
Corridor 02	922,42	158,70	0,172	0,1	YES

Building B					
ID	Floor area [m²]	Transparent area [m²]	Air/light ratio	Minimum air/light ratio	Verified?
Lab chemistry 01	229,90	111,59	0,500	0,1	YES
Lab chemistry 02	297,28	130,09	0,436	0,1	YES
Corridor 01	130,66	17,64	0,135	0,1	YES

Building C					
ID	Floor area [m²]	Transparent area [m²]	Air/light ratio	Minimum air/light ratio	Verified?
Café GF	148,53	93,09	626,000	0,1	YES
Offices / Administration	219,41	54,58	0,258	0,1	YES
Archives	148,53	93,09	0,626	0,1	YES
Corridor 01	130,66	17,64	0,135	0,1	YES