



VERIFICATION OF THE COMPLIANCE WITH ITALIAN REGULATIONS ABOUT AIR / LIGHT RATIO

Building A					
ID	Floor area [m²]	Transparent area [m²]	Air/light ratio	Minimum air/light ratio	Verified?
Meeting room 01	46,53	10,50	0,225	0,125	YES
Meeting room 02	46,53	10,50	0,225	0,125	YES
Meeting room 03	46,30	10,50	0,226	0,125	YES
Lab info 01	69,80	15,75	0,225	0,125	YES
Lab info 02	95,03	21,00	0,221	0,125	YES
Lab art 01	94,56	13,20	0,139	0,125	YES
Lab art 02	95,50	13,20	0,138	0,125	YES
Lab art 03	192,03	34,20	0,178	0,125	YES
Relax area	188,02	143,93	0,765	0,1	YES
Corridor	580,06	68,58	0,118	0,1	YES

Building B					
ID	Floor area [m²]	Transparent area [m²]	Air/light ratio	Minimum air/light ratio	Verified?
Lab physics 01	229,90	111,59	0,500	0,1	YES
Lab physics 02	297,28	130,09	0,436	0,1	YES
Corridor 02	130,66	17,64	0,135	0,1	YES

Building C					
ID	Floor area [m²]	Transparent area [m²]	Air/light ratio	Minimum air/light ratio	Verified?
Café FF	72,81	65,76	0,903	0,1	YES
Library	449,35	180,55	0,401	0,125	YES
Corridor 02	130,66	17,64	0,135	0,1	YES