



SPessori Isolanti TUBAZIONI CALDE D.P.R.412/93

CONDUTTIVITA' TERMICA (W/m°C) A 40°C	DIAMETRO ESTERNO DELLA TUBAZIONE (mm)	DA A 20-30	DA A 40-50	DA A 60-70	DA A 80-90	DA A 90-100
0,030	13	19	25	31	37	40
0,032	14	21	29	36	40	44
0,034	15	23	31	39	44	48
0,036	17	25	34	43	47	52
0,038	18	28	37	46	51	56
0,040	20	30	40	50	55	60
0,042	22	32	43	54	59	64
0,044	24	35	46	58	63	69
0,046	26	38	50	62	68	74
0,048	28	41	54	66	72	79
0,050	30	44	58	71	77	84



Albo: ALLEGATO TECNICO	Titolo di Laurea: Riqualificazione energetica edificio Installazione pompe di calore aria/acqua	12/2019
Candidato: Chiana SILVI	Titolo di Laurea: Schema centrale termica P&I componenti	00-A
Scelta: 1-1-1	Scelta: 1-MEC	MEC-01 test